

23-2417
Generator Removal, Replacement, and Installation

D Œ Z î ó U î î ð

Addendum #1:

On the original solicitation we left off the transfer switch that will also need to be included in this bid. We will require an ASCO104-amp automatic transfer switch which must be provided and installed as part of this bid package. Included in this addendum is an
